

**From:** Curtis, Samantha [REDACTED]  
**Sent:** 21 November 2014 15:02  
**To:** Chris Stanworth  
**Subject:** RE: Walltown - power supply query

Hi Chris,

In relation to the power supply to the cabin, I confirm that a scaffold pole is proposed to be mounted to the existing building to a maximum height of 3m (2m below ridge height) and a catenary wire support system to the ground floor eco cabin 3metres high, again using a scaffold pole. I also confirm that the type of cable will be a 10mm 3 core black insulated armoured cable.

Please let me know if you require any further information.

Kind regards,  
Sam

**Samantha Curtis**  
Planning Consultant  
Cundall  
D [REDACTED]  
T [REDACTED]  
[www.cundall.com](http://www.cundall.com)



Horsley House, Regent Centre, Gosforth, Newcastle upon Tyne, NE3 3LU, United Kingdom

Please consider the environment before printing this e-mail

---

**From:** Chris Stanworth [REDACTED]  
**Sent:** 20 November 2014 15:00  
**To:** Curtis, Samantha  
**Subject:** RE: Walltown - power supply query

Hi Sam

As discussed, excavation and undergrounding works in this area would require the submission of a plan/specification of the excavation and re-consultation with English Heritage and NNPA Historic Environment Officer. This would cause delays to the application and may or may not lead to a change to their existing comments.

Having spoken with Colin Wilson this morning, he has suggested that an alternative option would be to take the cable overground, which would avoid the need to re-consult heritage consultees and remove the risk of any heritage impacts. If your client wants to go ahead with the overground option, I think confirmation that the cable would link between the building and the cabins, the approx height of the cable and type of cable/method of connection proposed (if known) should be adequate information.

If you could confirm this ASAP that would be helpful. I have to have my report on this completed by Tuesday if it is to go on the agenda for DMC, so if you could let me know by Monday that would be appreciated.

Thanks  
Chris

---

**From:** Curtis, Samantha [REDACTED]  
**Sent:** 18 November 2014 16:23  
**To:** Chris Stanworth  
**Subject:** FW: Walltown - power supply query

Hi Chris,

Please see below confirmation on how the cabins will be powered.

Kind regards,  
Sam

**Samantha Curtis**  
Planning Consultant  
Cundall  
D [REDACTED]  
T [REDACTED]  
[www.cundall.com](http://www.cundall.com)



Horsley House, Regent Centre, Gosforth, Newcastle upon Tyne, NE3 3LU, United Kingdom

Please consider the environment before printing this e-mail

---

**From:** Colin Wilson [REDACTED]  
**Sent:** 18 November 2014 16:12  
**To:** Curtis, Samantha  
**Subject:** Re: Walltown - power supply query

Hello Sam

The porta cabins will be supplied with a electrical sub mains which will be connected to the existing service supply to the existing building and undergrounded from one to the other.

Colin

Sent from my HTC



---

Cundall Johnston & Partners LLP is a limited liability partnership registered in England and Wales. Registered number OC300389. Registered office: Horsley House, Regent Centre, Gosforth, Newcastle upon Tyne, NE3 3LU

All information contained in this email is private and confidential, and may also be privileged. This email and its attachments are intended solely for the use of the addressee only and if any third party whatsoever comes into possession of this email, they rely on it at their own risk and Cundall accepts no duty or responsibility (including in negligence) to any such third party. If you have received this email in error, please immediately notify the sender and delete all copies from your system.

Privacy Policy: Use of this email and any attachments is subject to the terms on our Website at <http://www.cundall.com/Policy>

If you cannot access these terms, please email [terms@cundall.com](mailto:terms@cundall.com) with SEND TERMS in the subject heading or telephone +44 (0191) 213 1515 and we will send you a copy.

All of our business is conducted in accordance with Cundall's Ethical Business Policy <http://www.cundall.com/Ethical-Business-Policy>

---

This email message has been scanned for viruses by Mimecast. For more information please visit <http://www.mimecast.com>

---

Chris Stanworth, Planning Officer  
Telephone: [REDACTED] Mob:  
Web: [www.northumberlandnationalpark.org.uk](http://www.northumberlandnationalpark.org.uk)

IMPORTANT NOTICE - Disclaimer - This communication is from Northumberland National Park Authority (NNPA). The Authority's head office and principal place of

business is Eastburn, South Park, Hexham, Northumberland, NE46 1BS, United Kingdom. If you are not the intended recipient(s) please note that any form of disclosure, distribution, copying or use of this communication or the information in it or in any attachments is strictly prohibited and may be unlawful. If you have received this communication in error, please delete the email and destroy any copies of it. Any views or opinions presented are solely those of the author and do not necessarily represent those of NNPA. Contractors or potential contractors are reminded that a formal Order or Contract is needed for NNPA to be bound by any offer or acceptance of terms for the supply of goods or services. Although this email and any attachments are believed to be free of any virus or other defects which might affect any computer or IT system into which they are received, no responsibility is accepted by the NNPA for any loss or damage arising in any way from the receipt or use thereof. Computer systems of this Authority may be monitored and communications carried out on them recorded, to secure the effective operation of the system and for other lawful purpose.