



ORIGINAL SIZE A1




1 01 - FOUNDATION PLAN  
1 : 20

NOTE


ALL LEVELS AND DIMENSIONS TO  
BE CONFIRMED BY ARCHITECT.



A SECTION A  
1 : 20



B SECTION B  
1 : 20



C TYPICAL EDGE  
THICKENING  
1 : 10

Notes

All dimensions to be checked on site and co-ordinated with relevant Architect's drawings. Any discrepancies to be reported to Engineer prior to fabrication.

Structural sizes hereon shall not be modified without the written approval of the Engineer.

This drawing is Copyright and should not be reproduced in whole or part without the written consent of the Engineer.

This drawing is to be read in conjunction with all relevant Patrick Parsons Ltd drawings & specifications.

All dimensions in mm unless noted otherwise.

All levels in metres.

Do not scale from this drawing.

NOTES:

1. ENSURE EXCAVATIONS REMAIN STABLE AT ALL TIMES.
2. BACKFILL ANY FOUNDATIONS TAKEN DEEPER THAN REQUIRED WITH MASS FILL CONCRETE.
3. IF FOUNDATIONS ARE NOT TO BE CAST ON SAME DAY THEN 50mm OF BLINDING SHOULD BE APPLIED TO TRENCH TO SEAL EXCAVATIONS.
4. NOTIFY ENGINEER IF:-  
A. THE FORMATION CONTAINS SOFT OR HARD SPOTS, OR HIGHLY VARIABLE MATERIAL.  
B. IF THE EXCAVATIONS ARE CONSIDERED TO BE BELOW THE WATER TABLE.
5. ALL CONCRETE TO BE GRADE RC35, U.N.O.
6. COVER TO ALL REINFORCEMENT TO BE 40mm U.N.O.
7. MIN. LAP LENGTHS :-  
MESH, SIDE AND END LAPS 400mm
8. ALLOW FOR 100Kg/m<sup>2</sup> OF REINFORCEMENT TO SLAB
9. ALLOW FOR 150 Kg/m<sup>2</sup> OF REINFORCEMENT TO THICKENING

Revisions

Rev	Description	Date	By
P02	2No. 150mm DUCTS ADDED. LEVELS AMENDED. UPDATED TO TENDER ISSUE	23.04.15	MS



Waterloo House  
Thornton Street  
Newcastle upon Tyne  
NE1 4AP

T. 0191 261 9000  
E. info@patrickparsons.co.uk  
W. www.patrikparsons.co.uk

Client  
NNPA/YHA

Project  
THE SILL, ONCE  
BREWED

Drawing  
BAT BARN -  
FOUNDATION  
ARRANGEMENT

Scales As indicated

Drawn AT  
Date APRIL 15  
Checked LRW

Status  
TENDER

Dig No. SIL-PP-00-00-M3-S-100  
Rev. P02