

THIS FORM IS FOR USE BY ELECTRICITY NETWORK OPERATORS TO ADVISE LOCAL PLANNING AUTHORITIES OF PROPOSED WORKS TO BE UNDERTAKEN WITHIN THEIR DESIGNATED AREA THAT ARE CONSIDERED TO BE EXEMPTED UNDER THE OVERHEAD LINES (EXEMPTION) (ENGLAND AND WALES) REGULATIONS 2009. LOCAL AUTHORITIES HAVE THE RIGHT TO INVOKE THE FULL SECTION 37 PROCESS UNDER THE ELECTRICITY ACT 1989 SHOULD IT BE CONSIDERED NECESSARY.

The Form should be sent in triplicate to each Local Planning Authority in whose area the proposed development would be situated.

Details of Applicant

Name: Northern Powergrid North East Limited

Contact Person: Jason Oakley

Address: Bell Ingram
Ellington Business Centre
Lynemouth Road
Ellington
NE61 5HB

Telephone No: [REDACTED]

Applicant's Ref: NC72355

Date: 27/05/2015

To: The Chief Executive, Northumberland National Park Planning Authority

Electricity Act 1989: Overhead Lines (Exemption)(England and Wales) Regulations 2009

It is proposed to undertake the following work that is considered to be exempted from the Electricity Act 1989 by falling within the Overhead Lines (Exemption)(England and Wales) Regulations 2009:

Rebuild of approximately 200 metres of LV overhead line.

Particulars of proposed development to be completed by Applicant:

This scheme proposes to improve the safety & reliability of the supply to the Simonburn area by the re-building of approx 200 metres of 120 mm ABC. This conductor is to be used on the entire length due to it's increased resilience to bird strikes than is older counterparts. I enclose a copy of drawing number C10047351 this shows in green the online conductor replacement, the work is within tolerance.

The Council/Authority is requested to indicate that it has no objection to the work being carried out by returning two copies of this Form with the Certificate completed and signed.

Yours Faithfully



For and on behalf of the Applicant

CERTIFICATE

**TO BE COMPLETED BY THE LOCAL PLANNING AUTHORITY AND RETURNED TO
THE APPLICANT ELECTRICITY NETWORK COMPANY WITHIN SIX WEEKS OF
RECEIPT**

Northumberland National Park Planning Authority

For scheme Hexham - Simonburn Falconary OHL

(i) objects/does* not object for the proposed development detailed above to be undertaken under the exemptions laid down in the Overhead Lines (Exemption)(England and Wales) Regulations 2009.

(ii) wishes/does* not wish the Secretary of State to consider the application using the full section 37 process under the Electricity Act 1989.

The reasons for requesting the full section 37 process are*:

Signed:
Designation:
on behalf of

Northumberland National Park Planning Authority

Dated:

*delete as appropriate

Applicant's Reference: NC72355

