



THIS FORM IS FOR USE BY ELECTRICITY NETWORK OPERATORS TO ADVISE LOCAL PLANNING AUTHORITIES OF PROPOSED WORKS TO BE UNDERTAKEN WITHIN THEIR DESIGNATED AREA THAT ARE CONSIDERED TO BE EXEMPTED UNDER THE OVERHEAD LINES (EXEMPTION) (ENGLAND AND WALES) REGULATIONS 2009. LOCAL AUTHORITIES HAVE THE RIGHT TO INVOKE THE FULL SECTION 37 PROCESS UNDER THE ELECTRICITY ACT 1989 SHOULD IT BE CONSIDERED NECESSARY.

The Form should be sent in triplicate to each Local Planning Authority in whose area the proposed development would be situated.

Details of Applicant

Name: Northern Powergrid (Northeast) Limited
Contact Person: Ross Anderson (Wayleave Officer)
Address: New York Road
Shiremoor
Newcastle upon Tyne
NE27 0LP

Telephone No: [REDACTED]

Applicant's Ref: DI72504

Date: 16/10/2015

To: The Chief Executive, Northumberland National Park Authority

Electricity Act 1989: Overhead Lines (Exemption)(England and Wales) Regulations 2009

It is proposed to undertake the following work that is considered to be exempted from the Electricity Act 1989 by falling within the Overhead Lines (Exemption) (England and Wales) Regulations 2009:

Replacement of existing Low Voltage overhead conductors with Aerial Bunched Conductor (ABC) and pole replacement works at Charlton and Boe Rigg, Bellingham, Hexham, Northumberland, NE48 1PE

Particulars of proposed development to be completed by Applicant:

In order to safeguard the security of electricity supplies in the area and reduce the Health & Safety Risk Northern Powergrid find it necessary to: Renew eight defective wood poles (in same location) and replace 10 spans of existing overhead conductor with Aerial Bunched Conductor (ABC) as shown on plan No. 008.

The Authority is requested to indicate that it has no objection to the work being carried out by returning two copies of this Form with the Certificate completed and signed.

Yours Faithfully

[REDACTED]

For and on behalf of the Applicant



CERTIFICATE

TO BE COMPLETED BY THE LOCAL PLANNING AUTHORITY AND RETURNED TO THE APPLICANT ELECTRICITY NETWORK COMPANY WITHIN SIX WEEKS OF RECEIPT

Northumberland National Park Authority

(i) ~~objects~~/does* not object for the proposed development detailed above to be undertaken under the exemptions laid down in the Overhead Lines (Exemption)(England and Wales) Regulations 2009.

(ii) ~~wishes~~/does* not wish the Secretary of State to consider the application using the full section 37 process under the Electricity Act 1989.

The reasons for requesting the full section 37 process are*:

Signed: [REDACTED]

Dated: 05/11/2015

Designation: HEAD OF DEVELOPMENT MANAGEMENT

on behalf of ***Northumberland National Park Authority***

*delete as appropriate

Applicant's Reference: DI72504