

**THIS FORM IS FOR USE BY ELECTRICITY NETWORK OPERATORS TO ADVISE LOCAL PLANNING AUTHORITIES OF PROPOSED WORKS TO BE UNDERTAKEN WITHIN THEIR DESIGNATED AREA THAT ARE CONSIDERED TO BE EXEMPTED UNDER THE OVERHEAD LINES (EXEMPTION) (ENGLAND AND WALES) REGULATIONS 2009. LOCAL AUTHORITIES HAVE THE RIGHT TO INVOKE THE FULL SECTION 37 PROCESS UNDER THE ELECTRICITY ACT 1989 SHOULD IT BE CONSIDERED NECESSARY.**

**The Form should be sent in triplicate to each Local Planning Authority in whose area the proposed development would be situated.**

### Details of Applicant

**Name:** Northern Powergrid North East Limited

**Contact Person:** Jason Oakley

**Address:** Bell Ingram  
Ellington Business Centre  
Lynemouth Road  
Ellington  
NE61 5HB

**Telephone No:** [REDACTED]

**Applicant's Ref:** NC72759

**Date:** 12/04/2016

**To: The Chief Executive, Northumberland National Park Planning Authority**

### Electricity Act 1989: Overhead Lines (Exemption)(England and Wales) Regulations 2009

It is proposed to undertake the following work that is considered to be exempted from the Electricity Act 1989 by falling within the Overhead Lines (Exemption)(England and Wales) Regulations 2009:

Bulk Building Clearance Issues Schemes

Particulars of proposed development to be completed by Applicant:

Following a recent survey it has been determined that the conductor wires need to be relocated in order to provide sufficient clearance to nearby building. It is proposed to rebuild the overhead line with 120 ABC conductor which will solve the clearance problem and improve the reliability of the supply. The length of conductor to be rebuilt at various locations totals approximately 650 metres these are shown in green on the attached plan and will be replaced in tolerance along the same route as the existing conductor with little or no visual impact.

The Council/Authority is requested to indicate that it has no objection to the work being carried out by returning two copies of this Form with the Certificate completed and signed.

Yours Faithfully

[REDACTED]

For and on behalf of the Applicant

CERTIFICATE

TO BE COMPLETED BY THE LOCAL PLANNING AUTHORITY AND RETURNED TO  
THE APPLICANT ELECTRICITY NETWORK COMPANY WITHIN SIX WEEKS OF  
RECEIPT

**Northumberland National Park Planning Authority**

For Scheme Bulk Building Clearance Issues Scheme

(i) objects/does\* not object for the proposed development detailed above to be undertaken under the exemptions laid down in the Overhead Lines (Exemption)(England and Wales) Regulations 2009.

(ii) wishes/does\* not wish the Secretary of State to consider the application using the full section 37 process under the Electricity Act 1989.

The reasons for requesting the full section 37 process are\*:

Signed: 

Dated: 18/05/2016

Designation: HEAD OF DEVELOPMENT MANAGEMENT

on behalf of **Northumberland National Park Planning Authority**

\*delete as appropriate

Applicant's Reference: NC72759