-----Original Message-----From: Web Master Sent: 15 November 2016 15:51 To: DC Consultation Subject: New comments for application 16NP0103

New comments have been received for application 16NP0103 from Duncan Wise duncan.wise@nnpa.org.uk

Address: Eastburn,South Park

Comments:

The application lies within Northumberland International Dark Sky Park. There is currently no reference to any exterior lighting requirements in the application. If any exterior lighting is needed, it should comply with the design guidelines set out in the Northumberland International Dark Sky Park Lighting Master Plan. Very simply, please ensure all new lighting fixtures are fully-shielded and emit less that 600 lumens each.

Web Master, Tel: (x)

IMPORTANT NOTICE - Disclaimer - Officers are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright or any other legal right by email communications. Any such communication is contrary to ICT policies and outside the scope of the employment of the individual concerned. Northumberland National Park Authority will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising.

DC Consultation, Development Control Consultation Tel: (x)

IMPORTANT NOTICE - Disclaimer - Officers are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright or any other legal right by email communications. Any such communication is contrary to ICT policies and outside the scope of the employment of the individual concerned. Northumberland National Park Authority will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising.