

**From:** [DC Consultation](#)  
**To:** [Margaret Telfer](#)  
**Subject:** FW: FW: Planning Consultation 17NP0004 - Twice Brewed Inn  
**Date:** 20 March 2017 13:50:24

---

---

**From:** Chris Stanworth  
**Sent:** 17 March 2017 08:16  
**To:** DC Consultation  
**Subject:** FW: FW: Planning Consultation 17NP0004 - Twice Brewed Inn

---

**From:** Gillian Plaice [REDACTED]  
**Sent:** 08 March 2017 11:47  
**To:** Chris Stanworth  
**Subject:** Fwd: FW: Planning Consultation 17NP0004 - Twice Brewed Inn

Link to document on DEFRA website

<https://www.gov.uk/government/publications/guidance-on-the-control-of-odour-and-noise-from-commercial-kitchen-exhaust>

**Gillian Plaice** BSc (Hons) MSc Cert. Ed. MCIEH MIOA  
**Environmental Health Officer**

**Public Health Protection Unit**

Environmental Protection Team  
Fire & Rescue Service  
Northumberland County Council  
West Hartford Business Park,  
Cramlington,  
Northumberland  
NE23 3JP

**Tel:** [REDACTED]

**Mobile:** [REDACTED]

**Email:** [REDACTED]

**Web Address:** [www.northumberland.gov.uk](http://www.northumberland.gov.uk)

**Please note that I work part-time and I will respond to your e-mail when next in the office.**

----- Forwarded message -----

**From:** Gillian Plaice [REDACTED]  
**Date:** 8 March 2017 at 11:44  
**Subject:** Fwd: FW: Planning Consultation 17NP0004 - Twice Brewed Inn  
**To:** Chris Stanworth <[Chris.Stanworth@nnpa.org.uk](mailto:Chris.Stanworth@nnpa.org.uk)>

Hi Chris,

Further to our telephone conversation just now, further information needs to be provided regarding the prevention of release of odours from the building. It appears from the information provided that odour from the process will simply be vented to atmosphere

with no abatement i.e. condensers or active charcoal. I attach a DEFRA guidance document which is primarily aimed at commercial kitchens however contains relevant information. I would expect some sort of odour abatement system to be installed to remove odours particularly during the boiling of wort and odours produced during the fermentation process. I accept that the building is some distance from the nearest receptors and that dispersal will be efficient, however, the applicant must demonstrate that no noticeable odour will be released into the air from the building.

I apologise for the delay in replying.

If you need any further information please give me a call.

kind regards  
Gill



[DEFRA Control of Odour and Noise from Commercia...](#)

**Gillian Plaice** BSc (Hons) MSc Cert. Ed. MCIEH MIOA  
**Environmental Health Officer**

**Public Health Protection Unit**

Environmental Protection Team  
Fire & Rescue Service  
Northumberland County Council  
West Hartford Business Park,  
Cramlington,  
Northumberland  
NE23 3JP

Tel: [REDACTED]  
Dir: [REDACTED]  
Mobile: [REDACTED]  
Email: [REDACTED]  
Web Address: [www.northumberland.gov.uk](http://www.northumberland.gov.uk)

**Please note that I work part-time and I will respond to your e-mail when next in the office.**

Chris Stanworth, Planning Officer  
Tel: 01434 611508 (x210)

**IMPORTANT NOTICE - Disclaimer - Officers are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright or any other legal right by email communications. Any such communication is contrary to ICT policies and outside the scope of the employment of the individual concerned. Northumberland National Park Authority will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising.**

DC Consultation, Development Control Consultation  
Tel: (x)

**IMPORTANT NOTICE - Disclaimer - Officers are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright or any other legal right by email communications. Any such communication is contrary to ICT policies and outside the scope of the employment of the individual concerned. Northumberland National Park Authority will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising.**