

To Whom it May Concern c/o Mr Matthew Stock Kidlandlee Morpeth Northumberland **NE65 7DA**

By e-mail:

Our Ref: C6325

01 June 2021

Dear Sirs.

Private Water Supply Abstraction Boreholes – Kidlandlee

Further to our recent correspondence I am writing to provide my professional E: opinion on the integrity and resilience of the private water supply network at Kidlandlee, with specific reference to the abstraction boreholes.

The boreholes were installed in 2002 with geological conditions in the area dictating completed drilling depths of over 90 metres below ground for an available yield of up to 1000 gallons per hour, or approximately 4500 litres per hour, proving to be available from either borehole. This yield is obviously well in excess of typical domestic demand and the last twenty years of use have proved the installations to be entirely reliable and the abstraction sustainable, even when allowing for the addition of the four further cottages to the network.

Regular servicing and maintenance has been undertaken on the water filtration equipment in accordance with the manufacturer's instructions at the recommended intervals, and consistent water quality has therefore been maintained at all times.

Whilst no guarantee of un-interrupted water supply can ever be offered by ourselves as contractors (nor can it by public supply delivery companies), there is no reason to suggest that the supply would fail to continue to deliver a sustainable Water Treatment supply of water for many years ahead.

Yours sincerely. For and on behalf of Dales Water Services Ltd.

Nick Dodds – Director

Registered Address: Witherick Lane Melmerby Ripon North Yorkshire HG4 5JB. UK



W: www.daleswater.co.uk

Borehole prognosis

Borehole Drilling

Abstraction Licencing

Pump Testing

Pump Installation

Water analysis

Private Water Supplies

Spring Water Assessment

Water Storage

Water boosting

Servicing and maintenance

Water Supply Management

Specialist Pump Pulling

Mini Crane Hire